

Attention:

Jeff Stephens/Rae Dick
Town of Westford
55 Main Street
Westford, MA 01886

Report Date: 6/22/2021

Date Sampled: 6/21/2021

Date Received: 6/21/2021

Date of Analysis: 6/21/2021

Summary Report

Sample Location	E.coli per 100 ml	Lab#
1 Nashoba Valley Tiki Beach 1	ND	229226
2 Nashoba Valley Tiki Pond 2	NT	
3 Summer Village Main Beach	18	229227
4 American Legion at LSFP	ND	229228
5 Lakeside Meadows (on Nab Lake)	4	229229
6 North Beach (on Nab Lake) N.I.A.	2	229230
7 Mary Lou Beach (on Nab Lake) N.I.A.	ND	229230
8 Sandy Beach (on Nab Lake) N.I.A.	ND	229230
9 Noble Cove (on Nab Lake) N.I.A.	18	229230
10 East Boston Camps (Girls Beach)	ND	229232
11 East Boston Camps (Daycare Beach)	4	229232
12 East Boston Camps (Boys Beach)	6	229232
13 Edwards Beach	4	229231
14 Forge Village Beach	2	229231

NT=Not Tested

ND=None Detected

DPH Limit = 235 cfu/100ml


Method of Analysis: EPA 1603

Massachusetts State Certified
Laboratory # = M-MA1118

RECEIVED

JUN 22 2021

WESTFORD
BOARD OF HEALTH


David L. Knowlton
Laboratory Director